

Rotary Screw Maintenance Log

Month _____ Year _____

Inspection & Service	Shift	Days of the Month															
		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
1. Every 8 Hours a. Check for advisories or shutdowns (record any)	1																
	2																
	3																
Every 8 Hours b. Check reservoir oil level Oil added? (N=No Y=Yes)	1																
	2																
	3																
Every 8 Hours c. Check for proper loading/unloading. (✓= done)	1																
	2																
	3																
Every 8 Hours d. Check discharge pressure (✓= done)	1																
	2																
	3																
Every 8 Hours e. Check discharge temperature (Record temperature)	1																
	2																
	3																
Every 8 Hours f. Drain condensate traps (✓= done)	1																
	2																
	3																
2. Every 125 Hours Check cooler and fan for dirt accumulation (✓= done)																	
3. Every 1000 Hours Change oil filter. Record hourmeter reading.																	
4. Change AEON Lubricant*** Change when advisory appears or when oil analysis indicates. Record hourmeter reading.																	
5. Every 12 Months Check pressure relief valve. (✓= done)																	
6. Every 18 Months Regrease motor. (✓= done)																	
7. Change Air Filter When advisory appears, change air filter. Record hourmeter reading.																	

*Or sooner, as indicated by advisory.

**Advisory for AEON9000 SP is programmed to appear at 8000 hours (earlier, if high discharge temperature exists.)

Rotary Screw Maintenance Log

Month _____ Year _____

Inspection & Service	Shift	Days of the Month														
		17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
1. Every 8 Hours	1															
a. Check for advisories or shutdowns (record any)	2															
	3															
Every 8 Hours	1															
b. Check reservoir oil level	2															
Oil added? (N=No Y=Yes)	3															
Every 8 Hours	1															
c. Check for proper loading/unloading. (✓= done)	2															
	3															
Every 8 Hours	1															
d. Check discharge pressure (✓= done)	2															
	3															
Every 8 Hours	1															
e. Check discharge temperature (Record temperature)	2															
	3															
Every 8 Hours	1															
f. Drain condensate traps (✓= done)	2															
	3															
2. Every 125 Hours Check cooler and fan for dirt accumulation (✓= done)																
3. Every 1000 Hours Change oil filter. Record hourmeter reading.																
4. Change AEON Lubricant** Change when advisory appears or when oil analysis indicates. Record hourmeter reading.																
5. Every 12 Months Check pressure relief valve. (✓= done)																
6. Every 18 Months Regrease motor. (✓= done)																
7. Change Air Filter When advisory appears, change air filter. Record hourmeter reading.																

*Or sooner, as indicated by advisory.

**Advisory for AEON9000 SP is programmed to appear at 8000 hours (earlier, if high discharge temperature exists.)