

POOL/SPA DAILY MAINTENANCE LOG

Facility Name:			Minimum Turnover Rate (GPM):		
Facility Address:			Month/Year:		
Date	Chlorine residual (free chlorine)	pH	Chemicals Added (type and amount)	Temp (°F)	Other Maintenance (backwash etc.)
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31					

Result of monthly cyanuric acid test: _____ ppm

Date of test: __ / __ / ____

Disinfectants in Pools:

Chlorine 1.0 to 10.0 ppm without CYA
2.0 to 10.0 ppm with CYA

Bromine 2.0 ppm, minimum

pH: 7.2 to 7.8 approved,
and 7.4 to 7.6 ideal

Cyanuric acid (CYA): 0 to 100 ppm approved ,
and 20 to 50 ppm ideal

Disinfectants in Spas, Wading pools & Spray grounds:

Chlorine 3.0 to 10.0 ppm

Bromine 4.0 ppm, minimum

Maximum water temperature: 104°F

Questions? Please call Sacramento County Environmental Health at (916) 875-8440.

Excerpts from the California
Health and Safety Code
The California Code of Regulations

116048. Record keeping for common interest development of less than 25 units

(a) On or after January 1, 1987, for public swimming pools in any common interest development, as defined in Section 4100 or 6534 of the Civil Code, that consists of fewer than 25 separate interests, as defined in Section 4185 or 6564 of the Civil Code, the person operating each pool open for use shall be required to keep a record of the information required by subdivision (a) of Section 65523 of Title 22 of the California Administrative Code, except that the information shall be recorded at least two times per week and at intervals no greater than four days apart.

(b) On or after January 1, 1987, any rule or regulation of the department that is in conflict with subdivision (a) is invalid.

§ 65523. Operation Records.

(a) Except as provided in Health and Safety Code, section 116048, the pool operator of every public pool open for use at a public pool site shall test the disinfectant residual and pH of the public pool water a minimum of once per day. The pool operator shall also test heated pools' water temperature a minimum of once per day. The pool operator may perform these daily tests using a properly calibrated automatic chemical monitoring and control system if approved by the enforcing agent and in accordance with the manufacturer's equipment specifications for calibration and directions for proper use. The pool operator shall maintain a written daily record of all test results, equipment readings, calibrations, and corrective action taken at the public pool site.

(b) If the pool operator adds cyanuric acid to a public pool, the pool operator shall measure the cyanuric acid concentration in that pool a minimum of once per month and shall maintain a written record of these test results and all corrective action taken at the public pool site.

(c) The pool operator shall test combined chlorine at a frequency required to maintain maximum combined chlorine concentrations below 0.4 ppm. The pool operator shall maintain a written record of these test results and all corrective action taken at the public pool site.

(d) The pool operator shall maintain a written record of routine maintenance and repairs to the public pool at the public pool site.

(e) If a fecal, vomit, blood contamination, near-drowning, or drowning incident occurs in a pool, the pool operator shall record the incident in accordance with the requirements of section 65546 and shall identify the affected public pool in the incident record if there is more than one pool at the public pool site. This record shall be maintained at the public pool site.

(f) The pool operator shall maintain data and records collected pursuant to subdivisions (a), (b), (c), (d), and (e) for at least two years for inspection by the enforcing agent and shall submit all data and records to the enforcing agent upon the agent's request.

Note: Authority cited: Sections 116048, 116050 and 131200, Health and Safety Code.

Reference: Sections 116035, 116040, 116043, 116050 and 116055, Health and Safety Code.

Questions? Please call Sacramento County Environmental Health at (916) 875-8440.

W:\Data\EH-PROGRAMS & PROJECTS\REC HEALTH\FORMS & DOCUMENTS\DAILY MAINTENANCE LOG.PDF