

## PRICE QUOTATION FORM

Quarterly Preventive Maintenance of Automatic Suppression System (AFSS) and Fire Detection and Alarm System (FDAS) of BFP-NHQ Building

\_\_\_\_\_  
Date

**Price Quotation No: BFP-SSVP RFQ15-017**

### Shopping and Small Value Procurement (SSVP) Committee

Bureau of Fire Protection - National Headquarters  
Agham Road, Bgry. Bagong Pag-asa, Quezon City

Sir:

After having carefully read and accepted the terms and conditions in the Request for Quotation, hereunder is our quotation for the item/s as follows:

Item No.	DESCRIPTION	QTY	ABC TOTAL PRICE	UNIT PRICE	TOTAL PRICE
1	<p><b>Quarterly Preventive maintenance of Automatic Suppression System (AFSS) of BFP-NHQ Building for One (1) year</b></p> <p><b>Required Services:</b></p> <p>1. General Service and Inspection of all components of the Automatic Fire Suppression System as a whole, including but not limited to, the following:</p> <ul style="list-style-type: none"> <li>a. Hydropneumatic test for pipes, fittings, valves and sprinkler heads.</li> <li>b. Visual Inspection of all regulating pressure.</li> <li>c. Manual testing for valves switches (open and close)</li> <li>d. Test and Visual inspection of: <ul style="list-style-type: none"> <li>• Fire Department Connection and Main Drain, and Fire Hose Cabinet.</li> </ul> </li> <li>e. Test of cut-in and cut-out of jockey pump/ fire pump</li> <li>f. Test inspection wiring and component of control panel.</li> <li>g. Testing and commissioning.</li> </ul> <p>2. Recommend repair and replacement of all parts of AFSS (if necessary);</p> <ul style="list-style-type: none"> <li>• Pipes and fitting, Sprinkler heads, Gauge, Auxiliary, Control Valves, Fire Department Connection, Main Drain, Fire Hose Cabinet, Jockey Pump, Jockey Pump Controller. Fire Pump, Fire Pump Controller Flow Meter, Waste Cone, Valves, Alarm Check Valves and Pressure Relief Valves.</li> </ul> <p><i>Notes:</i></p> <ul style="list-style-type: none"> <li>a. AFSS parts recommended to be repaired and/or replaced shall be subjected to further evaluation and approval of the General Services Section (GSS).</li> <li>b. No repair and/or replacement of parts shall be performed without the presentation of quotation of the service provider as well as evaluation and inspection report duly approved by the C, GSS.</li> <li>c. Payment shall be made as per submitted billing statement supported by final inspection report, pictures and other documentary requirements as required by COA.</li> </ul>	1 lot	320,000.00		

<p>3. Provide a one day training and orientation to the GSS personnel of basic troubleshooting of the system; and</p> <p>4. Conduct such other activities as may be necessary to maintain the optimum performance of the systems.</p> <p><b>Quarterly Preventive Maintenance of Fire Detection and Alarm System (FDAS) of BFP-NHQ building for One (1) year.</b></p> <p><b>Required Services:</b></p> <p>1. General Service and Inspection of all components of the Fire Detection and Alarm System as a whole, including but not limited to, the following:</p> <ul style="list-style-type: none"> <li>a. Check-up and cleaning of Smoke Detector. <ul style="list-style-type: none"> <li>• Wipe out, Chemical Contact Cleaner, Air blower, Vacuum Cleaning</li> </ul> </li> <li>b. Installation of Smoke Detector devices for proper fitting.</li> <li>c. Check-up and cleaning of Manual Push Station. <ul style="list-style-type: none"> <li>• Wipe out, Chemical Contact Cleaner, Air blower, Vacuum Cleaning</li> </ul> </li> <li>d. Installation of Manual Push Station for proper fitting.</li> <li>e. Check-up and cleaning of Fire Alarm Bell. <ul style="list-style-type: none"> <li>• Wipe out, Chemical Contact Cleaner, Air blower, Vacuum Cleaning</li> </ul> </li> <li>f. Installation Fire Alarm Bell for proper fitting.</li> <li>g. Inspection of panel trouble signal led's</li> <li>h. Inspectin of lead acid battery (swelling or loose connection)</li> <li>i. Test batteries-load voltage.</li> <li>j. Test and inspection of panel functionality, Led's, fuses,etc/ strobe or bell/solenoid/ wires</li> <li>k. Tightening screw connection and terminal logs</li> <li>l. Testing and commissioning</li> </ul> <p>2. Recommend repair and replacement of all parts of FDAS (if necessary)</p> <ul style="list-style-type: none"> <li>• Fire Alarm Control Panel, Smoke Detector, Manual Push Station Fire Alarm Bell</li> </ul> <p><i>Notes:</i></p> <ul style="list-style-type: none"> <li>a. <i>FDAS parts recommended to be repaired and/or replaced shall be subjected to further evaluation and approval of the General Services Section (GSS).</i></li> <li>b. <i>No repair and/or replacement of parts shall be performed withoutthe presentation of quotation of the service provider as well as evaluation and inspection report duly approved by the C, GSS.</i></li> <li>c. <i>Payment shall be made as per submitted billing statement supported by final inspection report, pictures and other documentary requirements as required by COA.</i></li> </ul> <p>3. Provide a one day training and orientation to the GSS personnel of basic troubleshooting of the system; and</p> <p>4. Conduct such other activities as may be necessary to maintain the optimum performance of the systems.</p> <p><b>Delivery Period: Seven (7) CD upon receipt of NTP</b></p> <p><b>Delivery Location: BFP-National Headquarters</b></p>				
	<b>Grand Total</b>	<b>320,000.00</b>		

The above quoted prices are inclusive of all cost and applicable taxes.

Very truly yours,

\_\_\_\_\_  
Name & Signature of Authorized Representative

\_\_\_\_\_  
Name of Company

\_\_\_\_\_  
Contact Number/s

\_\_\_\_\_  
Company Address

\_\_\_\_\_  
Email Address