



## Rough Framing Inspection Checklist-Engineered Wood Floor Joists (TJI's) **DRAFT**

<b>Address:</b>		<b>Contractor:</b>		<b>Permit #</b>	
-----------------	--	--------------------	--	-----------------	--

**The following checklist is not all-inclusive. Other code related requirements may be included in this inspection.**

OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	Verify that the work conforms to the approved plans, TJXPERT drawings, specifications, special conditions and field conditions. Unless the approved plans have been sealed by a design professional, TJXPERT drawings (or their equal) shall be available on the job site.	OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	Is there any special loading conditions, (such as a stick built roof, extra dead load associated with specific flooring materials) that is not addressed in the design drawings?
OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	Check to see that none of the joists have been damaged or repaired. Check that top or bottom flanges have not been cut.	OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	Verify that the required backer blocks and filler blocks have been installed at the stairway openings.
OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	Verify all squash blocks and blocking panels have been installed.	OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	Verify all bearing points continue through the joist assembly to the foundation.
OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	Verify all web stiffeners are installed.	OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	Verify that pressure treated sill plates and anchor bolts have been installed.
OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	Check locations and sizes of bored and rectangular holes.	OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	Verify the construction of any cantilevers.
OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	Other:	OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	Other:

Notes:

Date		Inspector	
------	--	-----------	--