

# Appendix B: Technical Benefit Cost Analysis

## Table of Contents

- Executive Summary ..... 1
- 1 Introduction..... 3
- 2 BCA Overview and Approach..... 3
- 3 Project Description ..... 4
  - 3.1 Base Case and Alternative ..... 5
  - 3.2 Project Impacts ..... 7
- 4 Benefits Measurement, Data, and Assumptions ..... 7
  - 4.1 Life Cycle Costs ..... 8
    - 4.1.1 Capital Costs ..... 8
    - 4.1.2 Annual Costs ..... 8
    - 4.1.3 Annual Savings ..... 10
    - 4.1.4 Life Cycle Costs Summary ..... 11
  - 4.2 Resiliency Value..... 12
    - 4.2.1 Methodology and Key Assumptions ..... 12
    - 4.2.2 Benefit Estimates ..... 18
  - 4.3 Environmental Value ..... 18
    - 4.3.1 Methodology and Key Assumptions ..... 19
    - 4.3.2 Benefit Estimates ..... 20
  - 4.4 Social Value..... 20
    - 4.4.1 Methodology and Key Assumptions ..... 20
    - 4.4.2 Benefit Estimates ..... 21
  - 4.5 Economic Revitalization..... 22
  - 4.6 Other Non-monetized Impacts..... 22
- 5 Project Risks and Implementation Challenges ..... 23
  - 5.1 Risks to Ongoing Project Benefits..... 23
  - 5.2 Project Implementation Challenges..... 23
- 6 Summary of Findings and BCA Outcomes ..... 25
- 7 Sensitivity Analysis ..... 26
  - 7.1 Results Using a 3% Discount Rate ..... 26

## List of Tables

TABLE 1: TABLE DESCRIBING BCA COSTS AND BENEFITS .....	2
TABLE 2: PROJECT EQUIPMENT SPECIFICATIONS .....	5
TABLE 3: PROJECT IMPACTS .....	7
TABLE 4: CAPITAL COSTS .....	8
TABLE 5: ANNUAL COSTS .....	9
TABLE 6: ANNUAL SAVINGS .....	11
TABLE 7: LIFE CYCLE COSTS SUMMARY .....	11
TABLE 8: ESTIMATED ECONOMIC IMPACTS OF A 12-HOUR POWER OUTAGE TO THE MARKETS AND BUSINESSES .....	14
TABLE 9: ESTIMATED ECONOMIC IMPACTS OF A 24-HOUR POWER OUTAGE TO THE MARKETS AND BUSINESSES .....	15
TABLE 10: ESTIMATED ECONOMIC IMPACTS OF A 36-HOUR POWER OUTAGE TO THE MARKETS AND BUSINESSES .....	16
TABLE 11: ESTIMATED ECONOMIC IMPACTS OF A 72-HOUR POWER OUTAGE TO THE MARKETS AND BUSINESSES .....	17
TABLE 13: INDIRECT ECONOMIC IMPACTS FROM RESILIENCY IMPROVEMENTS.....	18
TABLE 14: ENVIRONMENTAL AND SOCIAL VALUE KEY INPUTS .....	20
TABLE 15: ENVIRONMENTAL VALUE IMPACTS SUMMARY .....	20
TABLE 16: SOCIAL VALUE IMPACTS SUMMARY .....	21
TABLE 17: EMPLOYMENT .....	22
TABLE 18: SUMMARY OF MONETIZED IMPACTS.....	25
TABLE 19: BCA RESULTS.....	25
TABLE 20: SUMMARY OF MONETIZED IMPACTS (SENSITIVITY – 3% DISCOUNT RATE).....	27
TABLE 21: BCA RESULTS (SENSITIVITY – 3% DISCOUNT RATE).....	27

## List of Figures

FIGURE 1: BASE CASE CRITICAL FACILITIES AND THREATS .....	6
FIGURE 2: NATURAL GAS PRICE FORECAST.....	9
FIGURE 3: DIESEL PRICE FORECAST.....	9
FIGURE 4: NEW YORK CITY AVERAGE LBMP PRICE FORECAST .....	10
FIGURE 5: GENERATION CAPACITY COST ESTIMATES.....	11
FIGURE 6: HUNTS POINT FLOODPLAIN MAP.....	13
FIGURE 7: CRITERIA AIR CONTAMINANT EMISSIONS .....	22
FIGURE 8: MONETIZED HEALTH IMPACTS.....	22
FIGURE 9: SUMMARY OF MONETIZED COSTS AND BENEFITS .....	26
FIGURE 10: SUMMARY OF MONETIZED COSTS AND BENEFITS (SENSITIVITY – 3% DISCOUNT RATE).....	28

## Executive Summary

A total investment of \$71 million (\$20 million via the Rebuild by Design program, \$25 million contribution from New York City's larger CDBG-DR allocation, and \$26 million from New York City capital funds) is dedicated to the "continued robust planning and study related to the future of the food market and a small pilot/demonstration project (to be selected by the City)" in Hunts Point. The Hunts Point Resiliency Project meets the project purpose and need by identifying an energy resiliency pilot project and providing a sustainable, reliable and resilient energy solution to the Hunts Point area through a combination of power generation solutions. The pilot project comprises rooftop solar photovoltaic (PV) generation with battery energy storage systems, a microgrid with tri-generation, and backup generators for the supply of short- and long-term, dispatchable energy resiliency. All of the individual energy components that make up the complete Hunts Point Resiliency project have independent utility.

In conjunction with the implementation of the pilot project, there is a separate but related initiative to add rooftop solar PV generation under a community solar structure that would provide residents the option to purchase power directly from a solar developer and, in turn, receive monthly deductions on their Con Edison bills. The community shared solar project does not affect the independent utility of the Hunts Point Resiliency project.

The pilot project consists of the following components:

Microgrid with Tri-Generation – This component of the project involves a microgrid powered by a tri-generation system. The tri-generation system will supply full electrical power to the Produce Market, as well as re-capture and convert the waste heat to provide hot water for boilers at the Meat Market and chilled water for cooling at the Produce Market. In the event of an emergency when the electrical grid is not available, a section of the Con Edison distribution system in the Hunts Point area will be isolated from the grid via sectionalizing switches to form a microgrid.

Community Facility Solar/Storage Installations – To provide sustainable and resilient power supply to some of the primary community facilities, the project will involve the installation of rooftop solar photovoltaic generation and battery energy storage for both the Middle School (MS) 424 and Primary School (PS) 48.

Emergency Backup Generation for Businesses – To provide resilient power supply to some of the other buildings outside of the markets, the project includes the purchase of nominally four mobile diesel generators with the installation of transfer switches to allow the connection of these generators during emergency periods.

The Benefit-Cost Analysis (BCA) of the pilot project was prepared in line with US Department of Housing and Urban Development (HUD) requirements, other federal guidelines, and industry best practices. The **analysis period of 20 years** reflects the average useful life of equipment, all values are estimated using **constant 2016 prices** (depicted as 2016\$), **no general inflation** is used to escalate any values, and a **7% base discount rate** is used to bring all future values to a present value (PV) in 2016\$. The sensitivity section of the report also presents results using a 3% discount rate as is common practice for publicly funded projects as a proxy for the long-term federal government borrowing rate.

Overall, the **BCA shows positive outcomes with a \$27.2 million net present value, 1.29 benefit-cost ratio (BCR), and an internal rate of return (13.6%)** that is well above the 7% hurdle rate. With a 3% discount rate commonly used to assess publicly funded projects, the NPV increases to \$69 million and a BCR of 1.51. The top monetized project impacts are summarized in Table 1 and described in detail throughout this appendix.

Table 1: Table Describing BCA Costs and Benefits

Cost and Benefit by Category	Page # in Narrative Description	Qualitative Description of Effect and Rationale for Including in BCA	Quantitative Assessment	Monetized Effect, NPV (\$000s)	Uncertainty <sup>16</sup>
<b>Life Cycle Costs</b>					
<b>Capital Costs</b>	Pg. 8	Upfront one-time costs to implement the project and bring to operations.	Estimated by the Energy Resiliency Engineering Team based on costs of comparable recent project costs.	<b>(\$45,683)</b>	2
<b>O&amp;M Costs</b>	Pg. 8	Costs required to operate and maintain the system in a state of good repair during its service life.	Estimated by the Energy Resiliency Engineering Team based on costs of comparable recent project costs.	<b>(\$16,778)</b>	2
<b>Fuel Costs</b>	Pg. 8	Cost of fuel (diesel or natural gas) consumed by power generating equipment.	Fuel consumption estimated by the Energy Resiliency Engineering Team. Fuel price forecasts from NY State Energy Plan and EIA 2017 Annual Energy Outlook.	<b>(\$30,615)</b>	2
<b>Energy Cost Savings</b>	Pg. 10	Reduction in demand for electricity from the grid.	Electricity price are based on Bronx location-based marginal price forecasts from the NYISO 2015 CARIS.	<b>\$27,931</b>	2
<b>Generation Capacity Cost Savings</b>	Pg. 10	Avoided costs from deferring the need to invest in new bulk power generation.	Estimated reduction in demand for peaking capacity through demand response program participation and NYISO 2015 CARIS cost of generation.	<b>\$7,162</b>	2
<b>Resiliency Value</b>					
<b>Power Outage Reduction Benefits - Markets and Businesses</b>	Pg. 13	Avoided revenue and inventory losses from shut down operations during a major power outage event.	Revenue loss and inventory loss estimated based on market data and interviews with market representatives.	<b>\$57,208</b>	4
<b>Power Outage Reduction Benefits - Direct Wages</b>	Pg. 13	Reduced impacts on FDC businesses prevent the loss of wages of workers that would be out of work until the market could come back online.	Wage losses derived based on the number of employees obtained from NYCEDC Business Reporting and average employee wages – EMSI labor market data.	<b>\$1,694 (excluded from BCA total)</b>	4
<b>Power Outage Reduction Benefits - Indirect Impacts</b>	Pg. 13	Indirect losses from impacts on FDC businesses' sales.	Direct revenue losses derived from the market impacts; Regional multipliers obtained from IMPLAN.	<b>\$12,357 (excluded from BCA total)</b>	4
<b>Power Outage Reduction Benefits - Community Facilities</b>	Pg. 19	Energy packages enable community facilities to provide refuge to those in need during major weather and outage events, and other services to community members.	Estimated based on 1,200 person capacity and a value of \$331 per person per day based on US General Services Administration guidelines for federal per diem reimbursable expenses.	<b>\$459</b>	4
<b>Reliability Improvements</b>	Pg. 19	Avoided costs associated with the reduction in the frequency or duration of minor power outages.	Estimated annual cost of service interruption for each class of electricity customer with state-specific inputs using the US Department of Energy Interruption Cost Estimate Calculator.	<b>\$65.10</b>	2
<b>Environmental Values</b>					
<b>Greenhouse Gas (GHG) Emissions</b>	Pg. 19	Change in environmental damages from GHG emissions, net impacts of avoided GHG emissions from bulk energy suppliers, and increased emissions from implemented energy solutions.	Emission allowance prices are based on the NYISO 2015 CARIS. CO <sub>2</sub> emission damage costs are based on the Interagency Working Group on Social Cost of Greenhouse Gases, Technical Update of the Social Cost of Carbon for Regulatory Impact. NY grid marginal emission rates derived from the New York Public Service Commission Case 15-E-0703, the USEPA National Emissions Inventory and the Commission for Environmental Cooperation (North American Power Plant Emissions).	<b>\$3,285</b>	2
<b>Social Values</b>					
<b>Health Impacts</b>	Pg. 20	Net impacts of avoided criteria air pollutants causing mortality and respiratory issues from bulk energy suppliers and increased pollution from implemented energy solutions.	Criteria air contaminant emission costs are estimated based on the USEPA Cost-Benefit Risk Assessment Screening Model.	<b>\$27,212</b>	2
<b>Food Supply</b>	Pg. 22	Maintaining power to the markets would maintain food distribution to the region and avoid supply disruptions that could result in higher food prices.	+ (qualitative scale)	n/a	4
<b>Economic Revitalization</b>					

<sup>16</sup> Based on HUD guidelines – assessment of the certainty of the effect on a scale from 1 (very certain) to 5 (very uncertain).

<b>Employment Opportunity</b>	Pg. 22	The project will create temporary and permanent job opportunities during construction and operations.	+ (qualitative scale)	<b>55 people construction + 8 permanent &amp; 6 on-call</b>	<b>2</b>
-------------------------------	--------	---	-----------------------	---	----------

## 1 Introduction

This report presents the technical BCA of the energy resiliency pilot project for the Hunts Point Resiliency Project. This overall study process has been guided by a Sustainable Return on Investment (SROI) approach where several technology and project packages were developed, screened and evaluated. Ultimately, four project packages were formally evaluated using SROI, where preliminary BCA results for each package were reviewed, discussed and refined during a workshop session with the City, project team, and stakeholders. Based on this evaluation, one preferred pilot project was identified. The pilot project and BCA is summarized in the sections that follow.

## 2 BCA Overview and Approach

The BCA of the Hunts Point Resiliency project is developed using a SROI process whereby the analysis and assumptions are developed and then reviewed and refined with key stakeholders in a workshop environment. Using this approach, effects that can be quantified and expressed in monetary terms are monetized. Other effects which are relevant but which cannot be expressed in monetary terms are discussed qualitatively.

The BCA methodology employed is consistent with the general principles outlined in Office of Management and Budget (OMB) Circular A-94, “Guidelines and Discount Rates for Benefit-Cost Analysis of Federal Programs” as well as National Disaster Resilience Competition (NDRC) and other BCA guidelines relevant to the energy generation sector.<sup>17</sup>

BCA is a conceptual framework that quantifies in monetary terms as many of the costs and benefits of a project as possible. Benefits are broadly defined. They represent the extent to which people impacted by the project are made better off. In other words, central to BCA is the idea that people are best able to judge what is “good” for them, or what improves their well-being or welfare.

BCA also adopts the view that a net increase in welfare (as measured by the summation of individual welfare changes) is a good thing, even if some parties benefit, while others do not. A project or proposal would be rated positively if the benefits to some are large enough to compensate the losses of others.

Finally, BCA is typically a forward-looking exercise, seeking to anticipate the welfare impacts of a project or proposal over its entire life cycle. Future welfare changes are weighted against today’s changes through discounting, which is meant to reflect society’s general preference for the present, as well as broader inter-generational concerns.

The specific methodology developed for this energy resiliency pilot project was developed using core BCA principles and is consistent with HUD guidelines. In particular, the methodology involves:

- Establishing existing and future conditions under the alternative (build) and base (no-build) scenarios;

---

<sup>17</sup> This includes HUD BCA Guidelines, the New York Public Service Commission Order establishing the Benefit Cost Analysis Framework Proceeding on Motion of the Commission in Regard to Reforming the Energy Vision (January 21, 2016) and the New York State Energy Research and Development Authority’s Community Microgrid Benefit-Cost Analysis guide.

- Assessing benefits with respect to each of the five long-term outcomes identified in HUD’s requirements for Rebuild by Design projects<sup>18</sup> which are in line with NDRC BCA Guidance;
- Measuring benefits in dollar terms, whenever possible, and expressing benefits and costs in a common unit of measurement;
- Using standard benefit value assumptions adopted by federal agencies (i.e., Federal Emergency Management Agency - FEMA, Department of Transportation - DOT, etc.) while relying on industry best practices for the valuation of other effects;
- Estimating benefits and costs over a project life cycle that includes the project development period plus 20 years of operations consistent with the expected useful life of project assets;
- Discounting future benefits and costs with the real discount rates recommended by HUD (7%, and an alternative of 3% based on common industry practices and informed by federal guidance); and
- Engaging the City, technical experts and stakeholders in a workshop review to vet and refine project options, types of benefit and cost impacts, and key assumptions.

### 3 Project Description

The Hunts Point Resiliency Project meets the project purpose and need by reducing the peninsula’s vulnerability to coastal flooding through a pilot project that provides a reliable and resilient energy solution to the Hunts Point area through a combination of power generation solutions. The pilot project incorporates rooftop solar photovoltaic (PV) generation, battery energy storage, a CHP facility with microgrid, and other fossil fueled energy generation technologies for the supply of short- and long-term, dispatchable energy resiliency. In conjunction with the implementation of the pilot project, there is a separate but related initiative to add rooftop solar PV generation to a number of businesses under a community solar structure that would provide residents the option to purchase power directly from a solar developer and, in turn, receive monthly deductions on their Con Edison electricity bills.

The pilot project outlined herein consists of the following components, all of which offer independent utility.

Produce Market and Anchor Microgrid – This component of the Proposed Project involves a combined heat and power (CHP) facility consisting of two 2.6 MW reciprocating internal combustion natural gas engine generators with heat recovery hot water generators, two 400-ton two-stage absorption chillers, and two 300-ton single stage absorption chillers. The CHP facility will operate year round and supply electricity to the Con Edison grid that will offset a significant portion of the electrical loads of the Produce and Meat Markets, while exporting hot water to the Meat Market and chilled water to the Produce Market. The microgrid will use a portion of Con Edison’s existing infrastructure and will be completely separable from the larger grid so that the microgrid can operate independently from Con Edison in the event of an emergency. The CHP facility will control criteria air contaminants via the use of the latest emissions control equipment. The microgrid has independent utility and can provide full resiliency to the Produce Market. The microgrid would prevent inventory spoilage and enable the Produce Market to continue full produce distribution operations in the event of an emergency. When operating under emergency conditions, the CHP facility will also be able to continue export of about 1,100 tons of chilling load to the Produce Market. If necessary during emergency operations, the CHP facility will prioritize the use of hot water for purposes of producing chilled water to the Produce Market and limit the amount of hot water exported to the Meat Market. In this

---

<sup>18</sup> US Department of Housing and Urban Development: CDBG-DR Rebuild by Design: Guidance regarding content and format of materials for approval of CDBG-DR Action Plan Amendments releasing funds for construction of Rebuild by Design projects, including guidance for Benefit-Cost Analysis, April 2016.

case, the existing gas boilers at the Meat Market will be used to make-up the deficit in hot water to maintain operation of the Meat Market.

Community Facility Solar/Storage Installations – To provide sustainable and resilient power supply to two primary community facilities, the project will involve the installation of rooftop solar PV generation and battery energy storage for both the Middle School (MS) 424 and Primary School (PS) 48. The total supported installation is approximately 0.5 MW of solar capacity with eight hours of energy storage capacity for facility critical loads. This level of power will enable the facilities to provide shelter, refuge, or gathering spaces in emergency situations.

Emergency Backup Generation – To provide resilient power supply to other important citywide food distributors and employers in the Food Distribution Center that are also, the energy resiliency pilot project includes the purchase of four 275 kW, mobile diesel generators with the installation of transfer switches to allow the connection of these generators during emergency periods. This fleet of mobile generators enables immediate energy resiliency with minimal capital construction and costs for additional facilities that are critical to the city’s food supply chain.

The locations, capacities, and utilization of the various installations are summarized below in Table 2.

Table 2: Project Equipment Specifications

Project Location	Generation Type	Capacity (MW)	Purpose
<b>Produce Market</b>	CHP Facility	5.2	Produce and Meat Markets Resiliency / Microgrid
<b>MS 424</b>	Rooftop Solar PV	0.45	Community Resiliency
	Battery Storage	0.09	
<b>PS 48</b>	Rooftop Solar PV	0.04	
	Battery Storage	0.06	
<b>Other Businesses</b>	Mobile Diesel Generators	1.1	Business Resiliency
<b>Total Installed Capacity</b>		<b>6.9 MW</b>	

### 3.1 Base Case and Alternative

#### Base Case

The Base Case is defined as existing conditions and without the pilot project. The Hunts Point Resiliency study area as a whole faces its greatest threats from storm surge along areas of the coastline, building and system-level outages, and extreme heat. Economic resilience in the industrial area depends on physical resilience, i.e., staying in business, and the Food Distribution Center (FDC) businesses are part of a regional network of sellers and purchasers. Social resilience is directly dependent on the physical resiliency of community facilities and the ability of any new proposed project to address environmental justice concerns within the community.

Key points pertaining to the Base Case conditions include:

1. Building and system-level power outages are a significant and shared threat to residents and businesses in Hunts Point.
2. Due to considerable elevation change, the low-lying areas face significant threats from coastal flooding while the upland residential area does not.
3. Extreme rain/snow storms are not a major threat in Hunts Point.

4. The number of community organizations and history of organizing in Hunts Point can lay the foundation for strong social resiliency.

Several key economic centers including FDC facilities are vulnerable to a combination of building and system-level energy outages, storm surge, and extreme heat events. Food Center Drive, the main street to and from the FDC, would be under water in a 100-year storm tide and 2050 sea level rise. Social services in the residential areas and, specifically, the schools that serve as community centers and emergency shelters (PS 48 and MS 424), are vulnerable to energy outages and extreme heat due to the potential displacement of schoolchildren and employees during an outage or if these facilities could not be used during an emergency because of a lack of power or air conditioning. The future threats and vulnerable critical facilities based on an assessment of the base case completed for the Hunts Point Resiliency Project are summarized in Figure 1.

Figure 1: Base Case Critical Facilities and Threats

### Critical Facilities & Future Threats

Facility	Threat	
Hunts Point Recreational Center	Outage, Heat	Community
Pio Mendez Housing for the Elderly	Outage	
Primary School (PS) 48	Outage, Heat	
Middle School (MS) 424	Outage, Heat	
Produce Market	Outage, Heat	Food Distribution Center
Meat Market	Outage, Surge, Heat	
Fish Market	Outage, Heat	
600 Food Center Dr (Citarella/Sultana)	Surge	
Krasdale	Surge	
Hunts Point Wastewater Treatment Plant	Surge	Infrastructure & Other Facilities
Oak Point Railyard	Surge	
Vernon C. Bain Correctional Facility	Surge, Heat	
Certain Road Intersections	Surge, Outage	
Certain Electrical Transformers	Surge, Outage	

### Alternative Case

The Alternative Case assumes that Hunts Point Resiliency project is implemented as described above in the Introduction and Project Description.

### 3.2 Project Impacts

Implementation of Hunts Point Resiliency project would have several impacts including life cycle costs, resiliency, environmental, social, and economic impacts. These are briefly summarized below (Table 3) and are explored in more detail in the following section.

Table 3: Project Impacts

Category	Cost and Benefit by Category	Description of Effect
Life Cycle Costs	Capital Costs	Upfront one-time costs to implement the Energy Resiliency pilot project and bring the project to operation.
Life Cycle Costs	O&M Costs	Costs required to operate and maintain the system in a state of good repair during its service.
Life Cycle Costs	Fuel Costs	Cost of fuel (diesel or natural gas) consumed by power generating equipment.
Life Cycle Costs	Energy Cost Savings	Reduction in demand for electricity from the grid after pilot project implementation.
Life Cycle Costs	Generation Capacity Cost Savings	Avoided costs from deferring the need to invest in new bulk power generation after pilot project implementation.
Resiliency	Reliability Improvements	Avoided costs associated with the reduction in the frequency or duration of power outages after pilot project implementation.
Resiliency	Power Outage Reduction Benefits - Markets and Businesses	Avoided revenue and inventory losses from shut down operations during a major power outage event after pilot project implementation.
Resiliency	Power Outage Reduction Benefits - Direct Wages	Reduced impacts on FDC businesses prevent the loss of wages of workers that would be out of work until the market could come back online after pilot project implementation.
Resiliency	Power Outage Reduction Benefits - Indirect Impacts	Reduction in indirect losses from impacts on FDC businesses sales including avoided loss of economic activity by suppliers and consumers of the markets, as well as employee spending.
Resiliency	Power Outage Reduction Benefits - Community Facilities	Pilot project implementation enables the community facilities to provide refuge to those in need during major weather and outage events, and other services to community members.
Environmental	GHG Emissions	Change in environmental damages from GHG emissions, net impacts of avoided GHG emissions from bulk energy suppliers and local emissions offsets, and increased emissions from implemented energy solutions.
Social	Health Impacts	Net impacts of avoided criteria air pollutants causing mortality and respiratory issues from bulk energy suppliers and local emissions offsets, increased pollution from implemented energy solutions.
Social	Food Supply	Maintaining power to the markets would maintain food distribution to the region and avoid supply disruptions that could result in higher food prices.
Economic Revitalization	Employment Opportunity	The project will create temporary and permanent job opportunities during construction and operations.

## 4 Benefits Measurement, Data, and Assumptions

The BCA was prepared in line with HUD requirements, other federal guidelines, and industry best practices. The **analysis period of 20 years** reflects the average useful life of equipment, all values are estimated using **constant 2016 prices** (depicted as 2016\$), **no general inflation** is used to escalate any values, and a **7% base discount rate** is used to bring all future values to a present value (PV) in 2016\$. The sensitivity section

of the report also presents results using a 3% discount rate as is common practice for publicly funded projects as a proxy for the long-term federal government borrowing rate.

## 4.1 Life Cycle Costs

### 4.1.1 Capital Costs

The capital costs (Table 4) represent the full upfront one-time costs to implement the project and bring it to operations (regardless of ownership or funding structure). While all cost estimates are presented in 2016\$, construction is not anticipated to begin until the year 2020 with the bulk of it spent in 2021. Therefore, the estimated total expended capital cost value, accounting for escalation over the duration of the project execution, is \$71 million. The capital costs make up the far majority of the project costs. For the purposes of the BCA, the capital costs are presented exclusive of any financial credits or incentives for solar PV installations.

Table 4: Capital Costs

<b>Capital Costs</b>	<b>\$Millions</b>
Total capital costs, excluding credits (2016\$)	\$62.97
Total capital costs, excluding credits (YOES)	\$71.00
Present Value (2016\$)	\$45.68
Equipment Life	20 years

### 4.1.2 Annual Costs

#### 4.1.2.1 Operating & Maintenance Costs

The operating and maintenance (O&M) costs include both fixed and variable costs to operate and maintain the system in a state of good repair during its service life, including costs directly associated with power generation and excluding fuel. These costs will begin to be incurred once the project is operational in 2022 and through the final year of operation in 2041. The costs are assumed to escalate at the general level of inflation over the study period (and thus remain constant for the purposes of the BCA).

#### 4.1.2.2 Fuel Costs

Fuel costs were estimated based on the expected fuel consumption according to the equipment efficiency, frequency of use, and capacity utilization. Price forecasts for delivered fuel to the region were based on information from the New York State Energy Plan and the latest US Energy Information Administration (EIA) 2017 Annual Energy Outlook price forecasts presented below in Figures 3 and 4.

Figure 2: Natural Gas Price Forecast





Figure 3: Diesel Price Forecast



The sum of O&M and fuel costs adds up to approximately \$6.38 million per year. Given the 2022 in service date and a 7% discount rate, the discounted costs over 20 years sum to a total of \$47.39 million (Table 5).

Table 5: Annual Costs

Millions 2016\$	Present Value	Annual Average
O&M Costs	\$16.78	\$2.23
Fuel Costs	\$30.62	\$4.15
<b>Total Annual Costs</b>	<b>\$47.39</b>	<b>\$6.38</b>

### 4.1.3 Annual Savings


#### 4.1.3.1 Energy Cost Savings

The main financial benefits offsetting ongoing costs are the energy cost savings, which represent the avoided cost of generating electricity on the grid and delivering it to Hunts Point. The project is anticipated to generate approximately 46,178 MWh per year.

In order to estimate the actual gross generation displaced from the grid, the annual generation is marked up by an average distribution loss factor of 3.5%<sup>19</sup> while it is assumed that transmission losses are internalized in the Location Based Marginal Prices (LBMP) which reflect the marginal cost of generating electricity at a given point in time.

The actual value of avoided electricity generation from the grid was estimated based on the 5-year real time average LBMP in the Bronx during the hours the equipment is expected to operate. The 5-year average spread between the LBMP at those times and the average New York City zonal LBMP was then applied to the NYC zonal forecast in the latest New York Independent System Operator (NYISO) 2015 Congestion Assessment and Resource Integration Study (CARIS). The average price forecast is presented through year 2024 in Figure 5. For subsequent years, the prices are escalated using the wholesale natural gas price forecast from the EIA since the majority of marginal generators at peak times are natural gas.

Figure 4: New York City Average LBMP Price Forecast



Source: NYISO, 2015 Congestion Assessment and Resource Integration Study; 2016\$

#### 4.1.3.2 Generation Capacity Cost Savings

In addition to avoided costs of generating electricity, it is possible for energy solutions to reduce load on the system during coincident peak periods, and as a result displace or defer future investments in generation or distribution capacity (e.g. the need to install new infrastructure required to meet peak system loads). Given substantial investments in local distribution infrastructure by Con Edison, it is not anticipated that distribution capacity cost savings could be reasonably attributed as a benefit.

<sup>19</sup> NYSERDA, Assessment of Transmission and Distribution Losses in New York.

The cost savings were calculated by multiplying the 5,200 kW CHP system capacity and the 712 kW contribution from the solar and energy storage installations that are expected to participate in Demand Response by the installed capacity price forecasts in line with NY DPS BCA Guidance<sup>20</sup> based on 2015 Gold Book with updates through January 2016 as presented in the charts above. The estimates account for the reserve margin that regulated utilities must maintain above anticipated peak load and are relatively small in comparison to the energy cost savings. See Figure 7 and Table 6 below.

Figure 5: Generation Capacity Cost Estimates




Table 6: Annual Savings

Millions 2016\$	Present Value	Annual Average
Energy Cost Savings	\$27.93	\$3.80
Generation Capacity Cost Savings	\$7.16	\$0.95
<b>Total Annual Savings</b>	<b>\$35.09</b>	<b>\$4.75</b>

#### 4.1.4 Life Cycle Costs Summary

Overall, the project is expected to cost \$58 million over its life cycle from a societal perspective (without accounting for renewable energy financial incentives or customer electricity bill savings which are considered to be a transfer of wealth). Once operational, the project is expected to offset nearly all ongoing costs with energy and generation capacity cost savings (Table 7).

Table 7: Life Cycle Costs Summary

Millions 2016\$	Present Value	Annual Average
Capital Costs	(\$45.68)	
O&M Costs	(\$16.78)	(\$2.23)

<sup>20</sup> New York Public Service Commission Case 14-M-0101 – Proceeding on Motion of the Commission in Regard to Reforming the Energy Vision, Order Establishing the Benefit Cost Analysis Framework.

Fuel Costs	(\$30.62)	(\$4.15)
Energy Cost Savings	\$27.93	\$3.80
Generation Capacity Cost Savings	\$7.16	\$0.95
<b>Total Life Cycle Costs</b>	<b>(\$57.98)</b>	<b>(\$1.63)</b>

## 4.2 Resiliency Value

The project provides several resiliency benefit streams, some of which can reasonably be monetized. Specifically, new local generation will allow the local markets and businesses to continue operating, or at least maintain critical loads to prevent inventory losses, during a major power outage and provide shelter at community facilities. Installed permanent generation (like solar PV and the CHP facility with microgrid) will further improve power reliability for those facilities in cases of minor power outages.

### 4.2.1 Methodology and Key Assumptions


#### Major Outage Probability

The probability of a major power outage due to storm surge was estimated based on anticipated inundation rates of Con Edison transformers at Hunts Point and floodplain data for each transformer and the impacted facilities from FEMA Preliminary Flood Insurance Rate Maps. It was determined that Krasdale, Sultana, and Citarella could benefit most from mobile generators during a major inundation event, which would allow them to preserve inventory for up to three days. In discussions with Con Edison, it was established that in the event of a major storm event power may be shut off a few of hours in advance as a preventative measure, and it could take as long as 48 hours to reinstate assuming that the transformer is not completely inundated (and would thus have to be replaced with an even longer outage time). Subsequently, storm surge durations of 6 to 24 hours are anticipated to result in a 2-3 day outage to the impacted facilities.

In addition to storm surge modeling estimates, it was assumed that a major outage event would occur once every 20 years (in other words with a 5% probability per year) and would cause a 3-day power outage to the peninsula. The event could range from a major Hurricane Sandy-like event to extreme heat, or anything else that causes a major system shut down. Based on historical data on the frequency and duration of outages, the assumption was deemed to be a reasonable representation of the project's true resiliency benefits.

All power outage reduction benefits in this section are estimated based on these major outage probabilities, while reliability improvements are estimated based on Con Edison minor outage statistics for the Bronx.

Figure 6: Hunts Point Floodplain Map



### Power Outage Reduction – Markets and Businesses

Preventing and reducing power outages to local markets and businesses is the overall biggest benefit to the project. Avoiding revenue and inventory losses from shutting down operations during a storm or other major outage event preserves the substantial economic activity generated by the facilities.

The impacts of major outages on specific FDC facilities were estimated in discrete blocks of outage time (12 hours, 24 hour, 36 hours, and 72 hours without power) based on certain assumptions that were derived from interviews with market representatives and subsequently vetted with stakeholders for reasonableness. The key assumptions included the share of inventory lost due to spoilage (based on the type of inventory, turnover rates, ability to use existing backup generators, etc.), and the days to return to business (influenced by facility lighting, cleanup of lost stock, ability to conduct offsite operations, etc.) which generated direct revenue and inventory loss estimates.

Only the direct revenue and inventory economic impacts were considered for the BCA as they represent the consumer willingness to pay for these goods and services. The direct impacts were subsequently used to derive other key economic impact metrics that are not additive benefits within the BCA as they serve to measure the impact on economic activity rather than social welfare. “Wage losses,” a derived impact, was based on the number of employees from New York City Economic Development Corporation (NYCEDC) Business Reporting and average employee wages based on EMSI labor market data. The other derived is “regional economic benefits” based on the multiplier effect of reduced FDC business sales using IMPLAN economic multipliers.

Table 8: Estimated Economic Impacts of a 12-hour Power Outage to the Markets and Businesses

	Produce Market	Hunts Point Cooperative Meat Market	New Fulton Fish Market	Krasdale	Baldor Specialty Foods	Sultana + Citarella	Anheuser-Busch	GrowNYC Regional Greenmarket	Dairyland/ Chef's Warehouse
Days Power Outage	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
Inventory Lost	0.5	0.25	0.15	0	0	0	0	0	0
Days to return to business	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5

Assumptions on inventory lost and number of days to return to business based upon interviews with Market representatives. Number of days to return to business may be influenced by facility lighting (daylight versus all indoor lighting), cleanup of lost stock, or ability to conduct offsite operations. Greenmarket inventory and operations are assumed to be similar to the Produce Market. Baldor and Dairyland have emergency generators that would prevent damages for 24 hours.

Direct Damages

Building Damage									
Other Property Damage									
Inventory Loss	\$13,800,000	\$5,000,000	\$1,260,000	\$0	\$0	\$0	\$0	\$0	\$0
Revenue Loss	\$4,600,000	\$3,334,000	\$2,800,000	\$4,166,000	\$1,044,000	\$1,016,000	\$994,000	\$404,000	\$1,320,000
Wages Loss	\$330,000	\$224,000	\$105,400	\$34,760	\$110,000	\$11,000	\$45,500	\$9,680	\$16,830
Estimated Direct Damages	<b>\$18,400,000</b>	<b>\$8,334,000</b>	<b>\$4,060,000</b>	<b>\$4,166,000</b>	<b>\$1,044,000</b>	<b>\$1,016,000</b>	<b>\$994,000</b>	<b>\$404,000</b>	<b>\$1,320,000</b>

Lost wages are provided for reference and are not included in the total since wages paid are a component of Total Revenue.

Indirect Damages

Building Damage									
Other Property Damage									
Inventory Loss									
Revenue Loss	\$2,324,453	\$1,475,357	\$1,414,884	\$2,105,146	\$527,550	\$513,401	\$502,284	\$204,148	\$667,017
Impacts of Wages Lost	\$82,670	\$83,164	\$26,404	\$8,708	\$27,557	\$2,756	\$11,398	\$2,425	\$4,216
Estimated Indirect Damages	<b>\$2,324,453</b>	<b>\$1,475,357</b>	<b>\$1,414,884</b>	<b>\$2,105,146</b>	<b>\$527,550</b>	<b>\$513,401</b>	<b>\$502,284</b>	<b>\$204,148</b>	<b>\$667,017</b>

Lost wages are provided for reference and are not included in the total since wages paid are a component of Total Revenue.

Table 9: Estimated Economic Impacts of a 24-hour Power Outage to the Markets and Businesses

	Produce Market	Hunts Point Cooperative Meat Market	New Fulton Fish Market	Krasdale	Baldor Specialty Foods	Sultana + Citarella	Anheuser-Busch	GrowNYC Regional Greenmarket	Dairyland/Chef's Warehouse
Days Power Outage	1	1	1	1	1	1	1	1	1
Inventory Lost	1	0.75	0.45	0.5	0	0.25	0	0.75	0
Days to return to business	1.5	1	1	1	1	1	0.5	1.5	1.5

Assumptions on inventory lost and number of days to return to business based upon interviews with Market representatives. Number of days to return to business may be influenced by facility lighting (daylight versus all indoor lighting), cleanup of lost stock, or ability to conduct offsite operations. Greenmarket inventory and operations are assumed to be similar to the Produce Market. Baldor and Dairyland have emergency generators that would prevent damages for 24 hours.

Direct Damages

Building Damage									
Other Property Damage									
Inventory Loss	\$27,600,000	\$15,000,000	\$3,780,000	\$12,500,000	\$0	\$3,556,000	\$0	\$1,818,000	\$0
Revenue Loss	\$13,800,000	\$6,668,000	\$5,600,000	\$8,332,000	\$2,088,000	\$2,032,000	\$994,000	\$1,212,000	\$3,960,000
Wages Loss	\$990,000	\$448,000	\$210,800	\$69,520	\$220,000	\$22,000	\$45,500	\$29,040	\$50,490
<b>Estimated Direct Damages</b>	<b>\$41,400,000</b>	<b>\$21,668,000</b>	<b>\$9,380,000</b>	<b>\$20,832,000</b>	<b>\$2,088,000</b>	<b>\$5,588,000</b>	<b>\$994,000</b>	<b>\$3,030,000</b>	<b>\$3,960,000</b>

Lost wages are provided for reference and are not included in the total since wages paid are a component of Total Revenue.

Indirect Damages

Building Damage									
Other Property Damage									
Inventory Loss									
Revenue Loss	\$6,973,359	\$2,950,713	\$2,829,769	\$4,210,292	\$1,055,100	\$1,026,802	\$502,284	\$612,443	\$2,001,051
Impacts of Wages Lost	\$248,010	\$166,327	\$52,809	\$17,416	\$55,113	\$5,511	\$11,398	\$7,275	\$12,648
<b>Estimated Indirect Damages</b>	<b>\$6,973,359</b>	<b>\$2,950,713</b>	<b>\$2,829,769</b>	<b>\$4,210,292</b>	<b>\$1,055,100</b>	<b>\$1,026,802</b>	<b>\$502,284</b>	<b>\$612,443</b>	<b>\$2,001,051</b>

Lost wages are provided for reference and are not included in the total since wages paid are a component of Total Revenue.

Table 10: Estimated Economic Impacts of a 36-hour Power Outage to the Markets and Businesses

	Produce Market	Hunts Point Cooperative Meat Market	New Fulton Fish Market	Krasdale	Baldor Specialty Foods	Sultana + Citarella	Anheuser-Busch	GrowNYC Regional Greenmarket	Dairyland/Chef's Warehouse
Days Power Outage	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5
Inventory Lost	1	0.75	0.65	0.5	0.75	0.5	0	1	0.5
Days to return to business	2	2	1.5	2	2	2	1.5	2	2

Assumptions on inventory lost and number of days to return to business based upon interviews with Market representatives. Number of days to return to business may be influenced by facility lighting (daylight versus all indoor lighting), cleanup of lost stock, or ability to conduct offsite operations. Greenmarket inventory and operations are assumed to be similar to the Produce Market.

Direct Damages

Building Damage									
Other Property Damage									
Inventory Loss	\$27,600,000	\$15,000,000	\$5,460,000	\$12,500,000	\$4,698,000	\$7,112,000	\$0	\$2,424,000	\$3,960,000
Revenue Loss	\$18,400,000	\$13,336,000	\$8,400,000	\$16,664,000	\$4,176,000	\$4,064,000	\$2,982,000	\$1,616,000	\$5,280,000
Wages Loss	\$1,320,000	\$896,000	\$316,200	\$139,040	\$440,000	\$44,000	\$136,500	\$38,720	\$67,320
Estimated Direct Damages	<b>\$46,000,000</b>	<b>\$28,336,000</b>	<b>\$13,860,000</b>	<b>\$29,164,000</b>	<b>\$8,874,000</b>	<b>\$11,176,000</b>	<b>\$2,982,000</b>	<b>\$4,040,000</b>	<b>\$9,240,000</b>

Lost wages are provided for reference and are not included in the total since wages paid are a component of Total Revenue.

Indirect Damages

Building Damage									
Other Property Damage									
Inventory Loss									
Revenue Loss	\$9,297,812	\$5,901,427	\$4,244,653	\$8,420,584	\$2,110,199	\$2,053,604	\$1,506,852	\$816,590	\$2,668,068
Impacts of Wages Lost	\$330,680	\$332,654	\$79,213	\$34,832	\$110,227	\$11,023	\$34,195	\$9,700	\$16,865
Estimated Indirect Damages	<b>\$9,297,812</b>	<b>\$5,901,427</b>	<b>\$4,244,653</b>	<b>\$8,420,584</b>	<b>\$2,110,199</b>	<b>\$2,053,604</b>	<b>\$1,506,852</b>	<b>\$816,590</b>	<b>\$2,668,068</b>

Lost wages are provided for reference and are not included in the total since wages paid are a component of Total Revenue.

Table 11: Estimated Economic Impacts of a 72-hour Power Outage to the Markets and Businesses

	Produce Market	Hunts Point Cooperative Meat Market	New Fulton Fish Market	Krasdale	Baldor Specialty Foods	Sultana + Citarella	Anheuser-Busch	GrowNYC Regional Greenmarket	Dairyland/Chef's Warehouse
Days Power Outage	3	3	3	3	3	3	3	3	3
Inventory Lost	1	1	1	0.5	1	0.5	0	1	1
Days to return to business	4	4	3	4	4	4	2.5	4	4

Assumptions on inventory lost and number of days to return to business based upon interviews with Market representatives. Number of days to return to business may be influenced by facility lighting (daylight versus all indoor lighting), cleanup of lost stock, or ability to conduct offsite operations. Greenmarket inventory and operations are assumed to be similar to the Produce Market.

Direct Damages

Building Damage									
Other Property Damage									
Inventory Loss	\$27,600,000	\$20,000,000	\$8,400,000	\$12,500,000	\$6,264,000	\$7,112,000	\$0	\$2,424,000	\$7,920,000
Revenue Loss	\$36,800,000	\$26,672,000	\$16,800,000	\$33,328,000	\$8,352,000	\$8,128,000	\$4,970,000	\$3,232,000	\$10,560,000
Wages Loss	\$2,640,000	\$1,792,000	\$632,400	\$278,080	\$880,000	\$88,000	\$227,500	\$77,440	\$134,640
Estimated Direct Damages	<b>\$64,400,000</b>	<b>\$46,672,000</b>	<b>\$25,200,000</b>	<b>\$45,828,000</b>	<b>\$14,616,000</b>	<b>\$15,240,000</b>	<b>\$4,970,000</b>	<b>\$5,656,000</b>	<b>\$18,480,000</b>

Lost wages are provided for reference and are not included in the total since wages paid are a component of Total Revenue.

Indirect Damages

Building Damage									
Other Property Damage									
Inventory Loss									
Revenue Loss	\$18,595,624	\$11,802,853	\$8,489,307	\$16,841,167	\$4,220,398	\$4,107,207	\$2,511,420	\$1,633,181	\$5,336,136
Impacts of Wages Lost	\$661,359	\$665,308	\$158,426	\$69,663	\$220,453	\$22,045	\$56,992	\$19,400	\$33,729
Estimated Indirect Damages	<b>\$18,595,624</b>	<b>\$11,802,853</b>	<b>\$8,489,307</b>	<b>\$16,841,167</b>	<b>\$4,220,398</b>	<b>\$4,107,207</b>	<b>\$2,511,420</b>	<b>\$1,633,181</b>	<b>\$5,336,136</b>

Lost wages are provided for reference and are not included in the total since wages paid are a component of Total Revenue.

## Power Outage Reduction - Community Facilities

The rooftop solar PV and energy storage installations at MS 424 and PS 48 will add redundancy and allow the community facilities to ensure the provision of refuge to those in need during major weather and outage events, and other services to community members (cell phone charging, bathrooms, gathering point, information, etc.). Informed directly by NYC Emergency Management, the BCA accounted for at least 1,200 people to be accommodated at the schools in a major event. (Additional discussions with stakeholders indicated that the capacity could even accommodate more.) A monetary value of \$331 per person per day was used based on U.S. General Services Administration guidelines for federal per diem reimbursable expenses (including an average of \$257 for lodging and \$74 for meals and incidentals in New York City).

## Reliability Improvements

Reliability improvements were estimated using average annual frequency (SAIFI<sup>21</sup> of 16.56 outages per 1000 customers served) and duration (CAIDI<sup>22</sup> of 384.6 minutes) of minor outages based on Con Edison's 5 year historical performance statistics in the Bronx. The outage statistics along with other customer attributes were entered into the U.S. Department of Energy Interruption Cost Estimate (ICE) Calculator to generate the avoided annual cost of service interruptions.

The value of interruption costs is based on an econometric modeling of several surveys and studies of customer willingness-to-pay to avoid service unreliability or willingness to accept compensation for service interruptions.

### 4.2.2 Benefit Estimates

Overall, the power outage reduction benefits to the local markets and businesses is the biggest monetized resiliency benefit of the project, and collectively, resiliency benefits make up the majority of the total project benefits. See Table 12 and 13.

Table 12: Resiliency Value Impacts Summary

Millions 2016\$	Present Value	Annual Average
Power Outage Reduction – Markets and Businesses	\$57.21	\$7.57
Power Outage Reduction - Community Facilities	\$0.459	\$0.0608
Reliability Improvements	\$0.065	\$0.0086
<b>Total Resiliency Benefits</b>	<b>\$57.73</b>	<b>\$7.64</b>

Table 13: Indirect Economic Impacts from Resiliency Improvements

Millions 2016\$	Present Value	Annual Average
Avoidance of Wage Losses	\$1.69	\$0.13
Regional Economic Benefits	\$12.36	\$0.96

## 4.3 Environmental Value

Because ongoing generation associated with the Hunts Point Resiliency project is from solar PV installations or from the high efficiency CHP facility, which will offset existing air emissions, another benefit is the reduction in fossil fuel energy consumption and the reduction in criteria pollutant and greenhouse gas (GHG) emissions compared to the base case. Local emissions offsets will occur by converting approximately 50 truck trailer refrigeration units at the Produce Market from diesel operation to electric operation and exporting hot water to the Meat Market to replace gas boiler use with the operation

<sup>21</sup> System Average Interruption Frequency Index.

<sup>22</sup> Customer Average Interruption Duration Index.

of the CHP facility. All of the energy system components that make up the Hunts Point Resiliency project also have environmental benefits because they provide energy at the source and avoid transmission and distribution losses, which would require additional gross generation from the grid.

### 4.3.1 Methodology and Key Assumptions

Local GHG emissions were estimated based on technical specifications for the proposed engines and generators, as well as their operating characteristics, while emissions savings were estimated based on the equivalent amount of generation displaced from the grid (adjusted for transmission and distribution losses). The emission rates for the grid were based on the probable types of fuel on the margin and the average emission rates of plants with the same primary fuel source in New York State. The emission rates were compiled and cross-examined primarily from the U.S. Environmental Protection Agency (EPA) National Emissions Inventory; Commission for Environmental Cooperation (North American Power Plant Emissions),<sup>23</sup> and net metering case documents from the New York State Public Service Commission published in December 2015.<sup>24</sup>

The value of net GHG emissions in CO<sub>2</sub>-equivalent (CO<sub>2e</sub>) tons was determined based on value per ton from the Interagency Working Group on Social Cost of Greenhouse Gases, Technical Update of the Social Cost of Carbon for Regulatory Impact using the widely recommended 3% discount rate.

In addition to the estimated social value of GHG emissions, utilities in New York are subject to certain emission allowance costs for CO<sub>2</sub>, NO<sub>x</sub>, and SO<sub>2</sub> emissions which are internalized in LBMP prices. Consequently, while the approach to estimating the social value of changes in GHG emissions (as well as the social value or the health impacts of other pollutants in the next section) is appropriate, the benefits of avoided allowance costs are already captured as part of the LBMP in the “energy cost savings” impact category. As such, an adjustment is made to the overall BCA analysis results to deduct the overlap in benefits. A forecast for the actual values of allowances by pollutants were derived from the same NYISO 2015 Congestion Assessment and Resource Integration Study as the average LBMP price forecast.

Table 14 outlines the key inputs for estimating the environmental and social values of the project.

---

<sup>23</sup> Data last accessed and extracted January 2017.

<sup>24</sup> New York Public Service Commission Case 15-E-0703 – In the Matter of Performing a Study on the Economic and Environmental Benefits and Costs of Net Metering Pursuant to Public Service Law §66-n.

Table 14: Environmental and Social Value Key Inputs

<b>Emission Factors (lb/MWh)</b>	<b>Grid</b>	<b>Engines/Generators</b>
CO <sub>2</sub> Emissions	1,077	Varies by Equipment
NO <sub>x</sub> Emissions	0.5616	
SO <sub>2</sub> Emissions	0.5609	
PM <sub>2.5</sub> Emissions	0.0601	
VOC Emissions	0.0435	
<b>Emission Damage Cost (\$/ton)</b>		
CO <sub>2</sub>	\$43.49	\$43.49
NO <sub>x</sub>	\$13,288	\$49,661
SO <sub>2</sub>	\$58,254	\$201,216
PM <sub>2.5</sub>	\$410,548	\$1,973,626
VOC	\$287	\$1,843
<b>Emission Allowance Prices (\$/ton)</b>		
CO <sub>2</sub> Emission Allowance per Ton	\$6.53	n/a
NO <sub>x</sub> Emission Allowance per Ton	\$154.64	n/a
SO <sub>2</sub> Emission Allowance per Ton	\$0	n/a

### 4.3.2 Benefit Estimates

Unlike the impacts of criteria air contaminants which have more localized impacts, GHG emissions have a much broader impact on the Earth’s atmosphere. The project is anticipated to reduce GHG emissions by 7,626 tons per year resulting in a total benefit of \$3.29 million over the study period (Table 15).

Table 15: Environmental Value Impacts Summary

<b>Net GHG Emissions Impacts</b>	
Present Value (millions 2016\$)	\$3.29
Annual Average (thousand 2016\$)	\$452
Change in GHG Emissions (CO <sub>2e</sub> tons/year)	(7,626)

## 4.4 Social Value

The project is anticipated to generate social value through a reduction in pollution, resilient community development, potential economic savings that could be passed on to low-moderate income residents and households in the area, increased public awareness fostering energy savings, and maintenance of food supply during power outages – all of which are primarily qualitative considerations either due to the difficulty to defensibly monetize the impacts, or due to a lack of reliable and accurate data. The impacts on health from exposure to pollution are estimated for the purposes of the BCA. To account for existing air quality concerns in the Hunts Point community, the BCA took a conservative approach weighing negative health impacts in the local project area more heavily than the benefits for the greater regional area.

### 4.4.1 Methodology and Key Assumptions

Criteria air contaminant (CAC) emissions were derived using the same approach as the greenhouse gas emissions in the Environmental Value section above, and included NO<sub>x</sub>, SO<sub>2</sub>, PM<sub>2.5</sub>, and VOC emissions. The social value of each pollutant per ton of emissions was estimated using EPA’s Co-Benefit Risk Assessment Screening Model (COBRA). The model estimates the potential risk of health issues including

asthma, heart or lung disease, and other respiratory issues associated with a change in levels of specific pollutants.

The BCA aimed to properly reflect differences of localized emissions in the more densely populated and environmental justice community of Hunts Point relative to offsetting emissions from the grid, which could impact utilities all across the State. Industry and federal BCA guidance typically uses a single average value of CAC emissions (which would have yielded a net health benefit). However, for this BCA, increases in local emissions were estimated based on Bronx County values to account for existing air quality concerns in the Hunts Point community, while reduction in grid emissions were estimated based on New York State-wide values. The resulting estimates were substantially higher for the Bronx, valuing local emissions nearly five times higher than those displaced from the grid.

#### 4.4.2 Benefit Estimates

A reduction in net project emissions yields regional benefits in the form of a net reduction in pollution. Even with localized criteria air contaminant emissions conservatively valued approximately 4.8 times higher than New York State averages for generation displaced from the power grid, overall health impacts of the project result in a net benefit of \$27.2 million (Table 16 and Figures 8 and 9).

Table 16: Social Value Impacts Summary

<b>Net Health Impacts</b>	
Present Value (millions 2016\$)	\$27.21
Annual Average (millions 2016\$)	\$3.60
<b>Change in CAC Emissions (tons/year)</b>	
NOx Emissions	(23.54)
SO <sub>2</sub> Emissions	(13.69)
PM Emissions	(2.27)
VOC Emissions	4.26

Figure 7: Criteria Air Contaminant Emissions





Figure 8: Monetized Health Impacts



#### 4.5 Economic Revitalization

The project will create both temporary and permanent job opportunities during construction and operations. These employment estimates are based on labor required for past comparable installation projects. The project construction duration varies from only 2 months for the community generators, to 6-18 months for solar PV and energy storage installations, and 20 months for the CHP facility with microgrid resulting in an estimated average construction workforce of 55 people, as well as 10 permanent and 6 on-call employees going forward. These estimates assume staff required for individual installations and do not account for potential efficiencies between buildings where the same employees could service different equipment simultaneously.

In addition to direct employment, the project will provide training and development opportunities as well as serve to improve the competitive advantage of the Peninsula (Table 17).

In addition to direct employment, the project will provide training and development opportunities as well as serve to improve the competitive advantage of the Peninsula (Table 17).

Table 17: Employment

Construction Jobs	
Construction Workforce	55
Permanent Employment	10 permanent, 6 on-call

#### 4.6 Other Non-monetized Impacts

There are other potential effects that have not been monetized in the analysis that provide value to the community. These include:

- The ability for the Middle School (MS) 424 and Primary School (PS) 48 to support community and emergency functions in major power outages. This will enable the schools to either be used

as emergency gathering locations for the community, or to maintain core administrative functions. The BCA does not anticipate that the schools will stay open for students in major power outage circumstances.

- The FDC provides food products throughout NYC. Maintaining business function in major power outages secures food supply to the region. Without a secure supply during major outages, there will be food shortages that potentially result in higher food prices throughout the study area.

## **5 Project Risks and Implementation Challenges**

### **5.1 Risks to Ongoing Project Benefits**

The major ongoing benefit from Hunts Point Resiliency project is maintaining business functions at the Produce Market in the FDC, including the preservation of existing inventories at the market and other commercial facilities.

One risk that could disrupt this benefit is a major flood or storm event that disrupts business activity at the markets such that one cannot access the markets for an extended period of time or an event that results in significant property damage at the facilities that requires operations to be shut down for repairs. In this situation, while power is maintained from Hunts Point Resiliency project which includes flood protections as part of conceptual design, there could still be a loss of business function. The inventory would still be maintained, but ongoing revenues would not be preserved.

### **5.2 Project Implementation Challenges**

The screening of energy resiliency technologies and project packages considered constructability and implementation challenges as key criteria. Overall, the screening criteria were developed based on HUD funding requirements, the AWG's Implementation Principles (see Appendix A), and industry standards as referenced. The output of this screening process was a list of technologies with limited implementation challenges. In addition, only proven technologies were considered; project technologies were evaluated for their proven capability to provide the intended service.

From a constructability perspective, the following was considered:

- **Available & Suitable Space:** Project space requirements were evaluated against available useable space in the vicinity of the proposed application. Functionality was evaluated based on sufficient space, disposition (purchase, easement, or other agreement), geotechnical, hazardous waste, and underground utility constraints.
- **Ease of Permitting:** Projects were evaluated for regulatory and permitting considerations that may require more significant coordination, approvals, and/or schedules for implementation due to anticipated environmental impact or administrative considerations.
- **Required Infrastructure:** Projects were evaluated against the quantity and types of infrastructure improvements that would be required for the installation and operation of the facility. Availability of gas, water, structures, electrical interconnection, and other factors were considered.

From an implementation perspective, the following was considered:

- **Potential to Leverage Public or Private Funds:** Projects were evaluated for their potential to leverage public or private funds, with the identification of potential funding sources that have been successfully utilized for precedent projects/investments being evaluated more highly.

Projects could also be evaluated highly for potential to capitalize upon avoided losses, such as lowered flood insurance premiums.

- **Schedule (in years) to Plan, Design and Construct:** Projects were evaluated on the estimated time to plan, design, permit, and construct from completion of conceptual design in 2017.

As such, only the most realistic and feasible energy resiliency technologies and project packages passed the screening process at the outset. Some key requirements or risks are outlined below.

- **Con Edison Agreement:** Con Edison is a key partner for the design and construction of a first phase microgrid and solar plus storage project package. In addition, significant dependence upon utilization of the existing Con Edison infrastructure for the microgrid will require agreement on the terms and conditions of equipment utilization and system control, including different conditions under which Con Edison will depower its lines. A tidal surge, for example, could be such a condition when depowering and back up generation might be needed. However, tidal surge is not expected to impact the proposed microgrid infrastructure as Con Edison assessed the vulnerability of this infrastructure to coastal flooding and hardened transformers that were determined to be potentially vulnerable (that is, infrastructure below the design flood elevation). The City and Con Edison have also been coordinating regularly to ensure successful design and implementation of the pilot project and plan to draft an agreement regarding the terms and conditions of the project.
- **Regulatory:** Implementation of the Hunts Point Resiliency Project will involve federal, state, and local permits and authorizations. Permits and authorizations cannot be obtained until the project design is further advanced. Coordination with federal, state, and city agencies that are potentially involved in the environmental review and regulatory permitting processes have already begun. Further coordination will continue after the identification of the pilot project to ensure that all required permits and authorizations will be obtained prior to groundbreaking.
- **Stakeholder buy-in:** The City is conducting a robust stakeholder engagement process with design and facilitation support from the Interaction Institute for Social Change and additional outreach and engagement leadership from The Point Community Development Corporation. The City and community's engagement activities began in 2015 to inform the project scope before kickoff. Building upon efforts in 2015, engagement for the Hunts Point Resiliency Project now includes a multi-pronged approach designed to:
  - Disseminate information in order to educate the public;
  - Incorporate input directly into technical analyses; and
  - Coordinate with other community-based resiliency efforts, leadership training, and workforce/ economic development opportunities.

The engagement process and structure for this project are viewed as contributing factors to resiliency in the Hunts Point community by ensuring transparency, robust information flows, social learning, skill development and relationship/trust building. The stakeholders will continue to be engaged throughout conceptual design and environmental review for the pilot project.

## 6 Summary of Findings and BCA Outcomes

Overall, the BCA shows positive outcomes with a \$27 million net present value, 1.29 BCR, and a 13.6% internal rate of return that is well above the 7% hurdle rate. Tables 18 and 19 as well as Figure 10 below summarize the results by monetized impact category.


Table 18: Summary of Monetized Impacts

<b>All Monetized Impacts (Millions 2016\$)</b>	<b>Undiscounted</b>	<b>NPV (7%)</b>
Energy Cost Savings	\$76.02	\$27.93
Generation Capacity Cost Savings	\$18.96	\$7.16
Power Outage Reduction Benefits - Markets and Businesses	\$151.48	\$57.21
Power Outage Reduction Benefits - Community Facilities	\$1.22	\$0.46
Reliability Improvements	\$0.17	\$0.07
GHG Emissions	\$9.05	\$3.29
Health Impacts	\$72.05	\$27.21
Adjustment for Grid Emission Compliance Costs	(\$8.13)	(\$3.06)
<b>Total Benefits</b>	<b>\$320.80</b>	<b>\$120.26</b>
Capital Costs	(\$62.97)	(\$45.68)
O&M Costs	(\$44.53)	(\$16.78)
Fuel Costs	(\$83.03)	(\$30.62)
<b>Total Costs</b>	<b>(\$190.52)</b>	<b>(\$93.08)</b>
<b>Net Impact</b>	<b>\$130.28</b>	<b>\$27.18</b>

Table 19: BCA Results

<b>Millions 2016\$ - Discounted at 7%</b>	
Present Value of Benefits	\$120.26
Present Value of Costs	(\$93.08)
<b>Net Present Value (NPV)</b>	<b>\$27.18</b>
Benefit-Cost Ratio (BCR)	1.29
Internal Rate of Return (IRR)	13.6%
Discounted Pay-back Period (years)	10.23

Figure 9: Summary of Monetized Costs and Benefits



## 7 Sensitivity Analysis

### 7.1 Results Using a 3% Discount Rate

Presented below (Tables 20 and 21 and Figure 11) are sensitivity results using a 3% discount rate as is common practice for publicly funded projects as a proxy for the long-term federal government borrowing rate. In general, a higher discount rate typically impacts project benefits (which accrue over many years) more than costs (the bulk of which are up-front capital costs). As a result, the lower discount rate would substantially increase project benefits, resulting in a net present value of \$69 million and a BCR of 1.51.

Table 20: Summary of Monetized Impacts (Sensitivity – 3% Discount Rate)

<b>All Monetized Impacts (Millions 2016\$)</b>	<b>NPV (3%)</b>
Energy Cost Savings	\$48.18
Generation Capacity Cost Savings	\$12.17
Power Outage Reduction Benefits - Markets	\$97.20
Power Outage Reduction Benefits - Community Facilities	\$0.78
Reliability Improvements	\$0.11
GHG Emissions	\$5.70
Health Impacts	\$46.23
Adjustment for Grid Emission Compliance Costs	(\$5.21)
<b>Total Benefits</b>	<b>\$205.17</b>
Capital Costs	(\$54.73)
O&M Costs	(\$28.54)
Fuel Costs	(\$52.70)
<b>Total Costs</b>	<b>(\$135.97)</b>
<b>Net Impact</b>	<b>\$69.19</b>

Table 21: BCA Results (Sensitivity – 3% Discount Rate)

<b>Millions 2016\$ - Discounted at 3%</b>	
Present Value of Benefits	\$205.17
Present Value of Costs	(\$135.97)
<b>Net Present Value (NPV)</b>	<b>\$69.19</b>
Benefit-Cost Ratio (BCR)	1.51
Internal Rate of Return (IRR)	13.6%
Discounted Pay-back Period (years)	8.86

Figure 10: Summary of Monetized Costs and Benefits (Sensitivity – 3% Discount Rate)

