



Physical Address: 529 S Center St.  
 Mailing Address: PO Box 99  
 Office: 830.914.2330  
 TDD: 1.800.735.2988

Marion, Texas 78124  
 Marion, Texas 78124-0099  
 Fax: 830.420.4138  
 Website: [www.gvsud.org](http://www.gvsud.org)

### WATER SYSTEM FINAL FIELD ACCEPTANCE CHECKLIST

GVSUD Project No.: \_\_\_\_\_ Date: \_\_\_\_\_

Project Name/Address: \_\_\_\_\_

Engineer: \_\_\_\_\_ Contractor: \_\_\_\_\_

Project Type: \_\_\_ Developer \_\_\_ CIP \_\_\_ TxDOT \_\_\_ Joint \_\_\_ Other: \_\_\_\_\_

GVSUD Inspector: \_\_\_\_\_

ITEMS	YES	NO	NA	Remarks
Pre-walk thru punch list items completed	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	_____
All materials and installations comply with GVSUD	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	_____
Bedding material is an approved type and installed correctly	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	_____
Backfill and compaction approved with passing testing reports	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	_____
Valves open left, operate freely, and are in open position	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	_____
Valve boxes set level to proper grade with soil or concrete and level	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	_____
Valve box extensions centered and straight with tracer wire accessible	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	_____
Adjacent curb neatly notched with 'V' for Valves and 'X' for meter box	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	_____
Fire hydrants set to proper grade 3" to 6" below break away flange	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	_____
Fire hydrants newly painted, clear of traffic, & caps in place	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	_____
Fire hydrants fully operate under pressure	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	_____
Fire Hydrants marked. Street: Blue Type 2 RPM. Rural: Flag	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	_____
Meter boxes set to proper grade with top soil and level	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	_____
Meter boxes not set in driveways or sidewalks	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	_____
Meter angle stop in box set 9" to 10" below bottom of lid	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	_____
Blow-offs fully operate and installed per plans	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	_____
Air Relief Valves open, operational, & installed per plans	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	_____
Mains passed Hydrostatic pressure testing with test reports	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	_____

GREEN VALLEY SPECIAL UTILITY DISTRICT is an Equal Opportunity Provider and Employer  
 Complaints of Discrimination should be sent to:  
 USDA Director, Office of Civil Rights, Washington, DC 20250-9410

ITEMS cont..	YES	NO	NA	Remarks
Mains passed disinfection bacteriological testing with a TCEQ approved testing lab, and having copies of test reports	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	_____
Asphalt and Concrete surface restoration work acceptable	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	_____
Site cleaned, restored, and revegetated per specifications	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	_____
Plan of record and GIS approval has been accepted	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	_____

**Comments:** \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

---

**Contractor- Print Name and Title**

\_\_\_\_\_  
**Contractor Signature**

---

**Engineer- Print Name and Title**

\_\_\_\_\_  
**Engineer Signature**

---

**GVSUD Inspector Signature**

GREEN VALLEY SPECIAL UTILITY DISTRICT is an Equal Opportunity Provider and Employer  
 Complaints of Discrimination should be sent to:  
 USDA Director, Office of Civil Rights, Washington, DC 20250-9410